



**COWICHAN VALLEY REGIONAL DISTRICT
ENGINEERING SERVICES**

ADDENDUM NUMBER 1

**TENDER NO. ES-015-17 SOUTH OYSTER SCHOOL ROAD – WATERMAIN REPLACEMENT
May 18, 2017**

This Addendum shall be read in conjunction with and considered as an integral part of the Tender. Submitted Tenders shall include all items of this Addendum.

The Addendum is as follows:

A. Changes

1. Page 7, Contract Work, Mobilization and demobilization currently reads:

Description of Works	Unit	Quantity	Unit Rate (\$)	Total Amount (\$)
Mobilization and demobilization	LS	2		

REPLACE with:

Description of Works	Unit	Quantity	Unit Rate (\$)	Total Amount (\$)
Mobilization and demobilization	LS	1		

2. Location of the service for the Vacant Lot:

The following change will apply to the water service location for the vacant Lot, Lot 4, Plan 13107:

The water service is to be installed on the west side of the property, side-by-side with the service for 3716 South Oyster School Road at property line.

Clarifications

1. Will you require a Bid Bond with our Tender submission?

Answer: no, there is no bid bond required.

2. Will the Contractor be responsible to cover Archaeological Costs?

Answer: No, the contractor will not be responsible for these costs.



3. Will the owner provide a water supply for compaction/flushing/testing of works?

Answer: Yes, but a recently tested and approved DCVA assembly is to be provided by the Contractor.

4. Is there any contaminated materials within the project area that will impact our works?

Answer: No, not that we are aware.

5. Can concrete thrust blocks be mixed onsite with a rotating drum style mixer?

Answer: This is acceptable providing the Contractor ensures that the concrete reaches a compressive strength of 20 MPa.

6. The MOTi Permit noted work will be complete on or before June 24, 2017. Can this date be revised to reflect our submitted schedule?

Answer: Yes, MoTI will extend the Permit to reflect the timeline of the construction.

7. Item No. 26 on the MoTI Permit states, Two-way traffic to be maintained at all times. Will Single Lane Alternating Traffic be approved?

Answer: Yes, MOTi will allow single lane alternating traffic.

8. The Contractor will be responsible for disposal of removed material and parts.