



ADDENDUM NUMBER 1

ES-024-17 Ornamental July 17, 2017

This Addendum shall be read in conjunction with and considered as an integral part of the Request for Quotations. Respondents should acknowledge the addendum on Appendix B the Submission Form. The Addendum is as follows:

The submission deadline has been extended until July 27, 2017 @ 2 p.m.

Questions & Answers:

Q1: Can you provide pictures of the lighting to be replaced?

A1: Pictures can be viewed at the following link: <https://ln.sync.com/dl/063b25a60/62qbfu8p-4ieyvfbq-44qgp2nu-ju3d2aaa>

Q2: Appendix A – System requirements a) notes the proposed LED lamps will provide equivalent, or less light output (i.e. lumens) to existing lamps. Did you mean more?

A2: We want the equivalent or less. The lights are too bright as it is.

Q3: Can you please confirm if you are looking for an LED based lamp to replace the existing HID lamps currently installed in each luminaire type or are you looking for a complete fixture replacement utilizing an LED based driver and LED assembly.

A3: We want to replace current lamps with an LED lamp. We are not replacing fixtures or any other structures.

Q4: What is the wattage on the current lighting?

A4: All wattages were spec'd at 100w except for Arbutus which is 70w.

End of Addendum 1

Anthony Jeffery
Procurement Officer
Cowichan Valley Regional District
175 Ingram Street, Duncan, BC V9L 1N8
Email: purchasing@cvrd.bc.ca
Tel: 250.746.2580 / Toll free: 1.800.665.3955