



ADDENDUM NUMBER 3

R17-17 Currie Park Washroom Building

September 11, 2017

This Addendum shall be read in conjunction with and considered as an integral part of the Request for Proposals. Respondents should acknowledge the addendum on Appendix B the Submission Form. The Addendum is as follows:

The Addendum is as follows:

Please note the submission deadline has been extended to September 25, 2017 @ 2 p.m. local time.

Questions & Answers:

Q1. Is a fire rated wall required between the washroom and mechanical room?

A1. No.

Q2. Can this be a thickened slab or is a perimeter foundation required?

A2. Perimeter foundation is required.

Q3. Do gutters/downspout need to go to a rock pit?

A3. No. A splash pad is sufficient.

Q4. There is only one gable vent shown on the drawing. Should there be another at the opposite gable end?

A4. Yes, a second vent is required.

Q5. Is there a ventilation fan required in the washroom?

A5. Yes

Q6. Are there any lighting requirements?

A6. Yes. Minimum one strip light in each room and one exterior light above the washroom door.

End of Addendum 3

Anthony Jeffery
Procurement Officer
Cowichan Valley Regional District
175 Ingram Street, Duncan, BC V9L 1N8
Email: purchasing@cvr.bc.ca
Tel: 250.746.2580 / Toll free: 1.800.665.3955