



ADDENDUM NUMBER 2

R17-28 Chemoy-Dogwood Watermain Install & Replacement

December 18, 2017

This Addendum shall be read in conjunction with and considered as an integral part of the Request for Proposals. Respondents should acknowledge the addendum on Appendix A the Submission Form. The Addendum is as follows:

The Addendum is as follows:

Questions & Answers

Q1. The RFQ submission is by email. Do you still require hard copy Bid Bonds to be delivered to your office, or are email copies acceptable?

A1. We do not require bid bonds. The successful bidder will be required to provide performance & labour Materials bonds as per page 4 section B of the competition document.

Q2. Please confirm the required construction completion date if any.

A2. Ideally eight weeks from contract award should suffice.

Q3. In reference to the gas lines along the construction route may I please request the diameter and type of pressure for each of the lines?

A3. The majority of distribution gas lines on the island run at about 80 psi and are 2". The successful bidder will know after the one call is placed.

Drawings

The attached drawings replace those that were issued with the RFQ. The drawings reflect a 1.5 metre separation between new main and existing main. Once our Risk Assessment has been completed and satisfies WorkSafeBC requirements we will communicate this information via way of addenda.

RFQ Timetable

Please note the RFQ table below has been updated to accommodate the Risk Assessment:

Event	Date
Release of RFQ	December 6, 2017
Site Meeting	December 12, 2017
Deadline for Questions	December 14, 2017 @ 2 p.m. January 8, 2018 @ 2 p.m.
Deadline for Issuing Addenda	December 19, 2017 4 p.m. January 9, 2018 @ 4 p.m.
Submission Deadline	December 21, 2017 @ 2 p.m. January 15, 2018 @ 2 p.m. local time

End of Addendum 2

Anthony Jeffery
Procurement Officer
Cowichan Valley Regional District
175 Ingram Street, Duncan, BC V9L 1N8
Email: purchasing@cvrd.bc.ca
Tel: 250.746.2580 / Toll free: 1.800.665.3955

